

EPA Emissions Standards for Emergency Standby Diesel Generator Sets

Information Sheet # 27

1.0 Introduction

The US Environmental Protection Agency (EPA) issued its final exhaust emission regulations in 2010 for emergency Standby Diesel Generator Sets, which took effect on January 1, 2011.

This Information Sheet discusses the regulations for diesel standby sets and generator set systems that qualify.

EPA began to enforce limitations on exhaust emissions for off-highway diesel engines in 1996, and in 2006, for stationary diesel generator sets. These 'progressive' regulations (called Tier levels) became more stringent over the intervening years and have had a major effect in substantially lowering the levels of nitrogen oxide (NOx), carbon monoxide (CO), particulate matter (PM) and non-methane hydrocarbons (NMHC). (Continued over)

Horse Power	TABLE 1. TIERS 1 - 4 RELATING TO STATIONARY NON-EMERGENCY & MOBILE GENERATOR SETS																					
<11																						
>11 - <25																						
>25 - <50																						
>50 - <75																						
>75 - <100																						
>100 - <175																						
>175 - <300																						
>300 - <600																						
>600 - <750																						
>750																						
Year	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017

i = interim Tier 1 Tier 2 Tier 3 Tier 3 Flexibility Tier 4i Tier 4i Flexibility Tier 4 Final

Horse Power	TABLE 2. APPLICABLE TIERS for STATIONARY EMERGENCY STANDBY POWER (ESP)									
<11										
>11 - <25										
>25 - <50										
>50 - <75										
>75 - <100										
>100 - <175										
>175 - <300										
>300 - <600										
>600 - <750										
>750 - <3000										
>3000										
Year	April 2006	2007	2008	2009	2010	2011	2012	2013	2014	

Tier 1 Tier 2 Tier 3 Tier 4

To fulfill our commitment to be the leading supplier and preferred service provider in the Power Generation Industry, the Central Power Systems & Services team maintains up-to-date technology and information standards on Power Industry changes, regulations and trends. As a service, our **Information Sheets** are circulated on a regular basis, to existing and potential Power Customers to maintain awareness of changes and developments in engineering standards, electrical codes, and technology impacting the Power Generation Industry.

The installation information provided in this information sheet is informational in nature only, and should not be considered the advice of a properly licensed and qualified electrician or used in place of a detailed review of the applicable National Electric Codes and local codes. Specific questions about how this information may affect any particular situation should be addressed to a licensed and qualified electrician.

Liberty - Corporate Office
9200 Liberty Drive
Liberty, MO 64068
816.781.8070 Ph
816.781.2207 Fax

Liberty, MO Branch
1900 Plumbers Way
Liberty, MO 64038
816.415.6700 Ph
816.415.6767 Fax

Springfield, MO Branch
3100 E. Kearney
MO 65803
417.865.0505 Ph
417.865.4304 Fax

Wichita, KS Branch
4501 W. Irving
KS 67209
316.943.1231 Ph
316.943.4560 Fax

Salina, KS Branch
1944B N. 9th St.
KS 67401
785.825.8291 Ph
785.825.8282 Fax

Great Bend, KS Branch
625 E. 10th St.
KS 67530
620.792.1361 Ph
620.792.1364 Fax

Colby, KS Branch
1920 Thielen Ave.
KS 67701
785.462.8211 Ph
785.462.8286 Fax

Liberal, KS Branch
1150 E. Hwy. 54
KS 67901
620.624.7274 Ph
620.624.7277 Fax

Woodward, OK Branch
127 NW Hwy. 270
OK 73801
580.256.6014 Ph
580.256.0314 Fax



(Continued from previous page)

By the time that Tier 4 Final regulations are introduced in 2013 and 2014 (Table 1), the NOx and PM levels from diesel exhaust will have been reduced by 99%. These Tier levels were introduced and ‘staggered’ over this time frame, dependent on the generator diesel engine horsepower (or metric mechanical kW equivalent) and NOT the kW output per the generator nameplate.

Diesel engine manufacturers were able to achieve compliance by in-engine or internal design changes (e.g. combustion chamber, fuel injection pressure, valve timing, cooled exhaust gas recirculation, and engine controls) to meet the Tier 2 and Tier 3 regulations and this has resulted in an emission reduction improvement of more than 85%.

2.0 Alternative standard (see table 2 overleaf)

EPA has found that the low exhaust emission rates with Tier 2 and Tier 3 engines will be acceptable for Emergency Standby Power (ESP) installations and thus they are exempt from the need to use Tier 4 Interim and Tier 4 Final diesel engines. The smaller HP sizes (below 50hp) however already are required to comply with Tier 4 Interim (since 2008). In addition, ESP’s normally only run for less than 200 hours per year and thus have a very small impact on the local air quality. There is no limit to the number of hours run in true emergency occasions such as utility outages or equipment malfunctions. This means that such generators will be in compliance with EPA through 2015 and beyond where they are used strictly for emergency duties. Currently, they will be allowed to be run for up to 100 hours per year for testing and maintenance purposes. This definition is under review and may be increased later in 2011.

3.0 Definition of “Emergency Standby” Applications.

These are generator installations that ONLY operate (i.e. limited operation) upon the loss of a normal power source such as the utility or mains grid. In this instance, when the normal power source is lost, the emergency generator starts to supply the electrical loads. Once the normal power source is reestablished and the emergency generator shuts down, these electrical loads are once again supplied from the normal source.

All operation of an emergency generator MUST be recorded by the user and referenced to a non-resettable hour recorder fitted to the genset. Any new emergency diesel engines that are built after the effected introduction date of the Tier 4 regulation MUST also be fitted with a permanent label stating that they are only for emergency use.

4.0 Exemptions.

State and local authorities may dictate stricter regulated emissions limits. For example, the State of California will not exempt emergency diesel generators with these applicable EPA rules in 2011 and will enforce even lower regulations for non-emergency stationary engines. This will result in the large majority of generator sets sold into California to require the supply of exhaust after-treatment devices, beginning in 2011.

Certain regions and locations in the United States of America may also enforce more stringent stationary emission regulations than the EPA diesel engine Tier levels. These include non-attainment areas, normally large population centers, where either high local emissions, local weather conditions, or ozone concentrations exceed the EPA air quality standard recommendations. For example, we can refer to such as areas of Southern California; areas of many New England states; Atlanta, Georgia; and Houston, Texas. This means that a stationary diesel-fueled emergency generator set – even if certified to the appropriate EPA Tier level, may not meet the local requirements. As the EPA lowers National Ambient Air Quality levels across the nation, more areas are likely to fall into non-attainment status and therefore further engine emission regulations are likely to be implemented.

5.0 Further Reading

The final authority on emissions regulations governing emergency standby diesel generator sets rests with Environmental Protection Agency (EPA) for access to their site go to:

www.epa.gov